



Hager-Lumetal SpA - Italy

Subsidiary Product Information (S.P.I.)

N.:

S.P.I. 09 – 11

 Product modification

 Product availability

 Product cancellation

Responsibility:

Product manager responsible: **Fabrizio Celot**Request origin: **AQ**

Note or Attachments: --

Date: **30 November 2011** Signature: --

Description:

Item description: **Certification EN 62208:2003 –empty enclosures for equipment**

Reference nr.: --

Brand: **HAGER**

EAN code: --

Product family: **univers**

Additional information

With reference to the product family on subject, you can find attached the following certificates:

- **IMQ approval certificate**
- **Cenelec Certificate Agreement (CCA)**

Please put the certificates into your catalogue.

Product modification – Mod. Date: --

Achieved:

Stock out: yes no

Packing labeling: --

For a term of: --

Product cancellation/availability – Date: --

Achieved:

Stock out: yes no

Distributed by e-mail or fax to the following subsidiaries:

 Germany Spain France Italy England Greece Belgium

 Portugal Switzerl. All countries

SUBSIDIARY INFORMATION FLOW: PM (HLT) > PM /MM(subsidiary)

PID:
02701200
CID:
C.1993.5553

Certificato di approvazione

Approval certificate

IMQ, ente di certificazione accreditato, autorizza la ditta *IMQ, accredited certification body, grants to*

**HAGER LUMETAL SPA
VIA PIEVE 27
33080 PORCIA PN**

all'uso del marchio

the licence to use the mark

IMQ

Il presente certificato è soggetto alle condizioni previste nel "Regolamento IMQ - Certificazione prodotto" ed è relativo ai prodotti descritti nell'Allegato al presente certificato.



per i seguenti prodotti

**Involucri vuoti per
apparecchiature assiemate di
protezione e manovra per bassa
tensione
(Serie univers)**

for the following products

*Empty enclosures for low-voltage
switchgear and controlgear
assemblies
(Series univers)*

This certificate is subjected to the conditions foreseen by "IMQ Rules - Product Certification" and is relevant to the products listed in the annex to this certificate.

Emesso il / Issued on **2004-10-11**
Aggiornato il / Updated on **2011-10-11**
Sostituisce / Replaces **2004-10-11**


IMQ S.p.A.

Allegato - Certificato di approvazione
Annex - Approval certificate

Emesso il / Issued on 2004-10-11
Aggiornato il / Updated on 2011-10-11
Sostituisce / Replaces 2004-10-11

Prodotto | Product

***Involucri vuoti per apparecchiature assiemate di protezione
e manovra per bassa tensione***
***Empty enclosures for low-voltage switchgear and
controlgear assemblies***

Concessionario | Licence Holder

HAGER LUMETAL SPA
VIA PIEVE 27
33080 PORCIA PN

Marchio | Mark



IMQ

Costruito a | Manufactured at

95002546 CLHAGL.C02LCHAGL+1 33080 PORCIA

PN Italy

*Copia del presente certificato deve essere conservata presso i luoghi di produzione
sopra elencati.*

Copy of this certificate must be available at the manufacturing places listed above

Norme

EN 62208:2003
Prodotti conformi ai requisiti essenziali della Direttiva B.T. 2006/95/CE

Standards

EN 62208:2003
Products meeting the essential requirements of L.V.D. 2006/95/EC

Rapporti | Test Reports

02LL00012

Caratteristiche tecniche | Technical characteristics

<i>Serie Series</i>	univers
<i>Classificazione Classification</i>	involucri vuoti per apparecchiature / empty enclosures for equipment
<i>Metodo di fissaggio Method of fixing</i>	a pavimento / floor standing
<i>Materiale dell'involucro Material of the enclosure</i>	composto / composite
<i>Grado di protezione Degree of protection (IP)</i>	IP54 porta chiusa - IP30 porta aperta / IP54 closed door - IP30 opened door
<i>Temperatura installazione Installation temperature</i>	T -5 / +40 °C
<i>Condizioni di servizio Service conditions</i>	normali / normal
<i>Luogo installazione Intended location</i>	interno / indoor
<i>Grado di protezione meccanico IK IK code</i>	IK10
<i>Carico statico Static load</i>	vedere Allegato 1 / see Annex 1
<i>Tensione nominale di isolamento Rated insulation voltage</i>	690 V

Articoli (con dettagli) | Articles (with details)

AR.E00978

<i>Marca Trade mark</i>	hager (logo)
<i>Riferimento di tipo Type reference</i>	univers
<i>Articolo/riferimento a catalogo Article/catalogue reference</i>	vedere Allegato 1 / see Annex 1
<i>Numero di moduli/dimensioni Number of modules/dimensions</i>	vedere Allegato 1 / see Annex 1
<i>Descrizione Description</i>	vedere Allegato 1 / see Annex 1

Diritti di concessione | Annual Fees

SN.E001HW

BTL.027000.DA1N

*Diritti serie IMQ - 0270 - Scatole di derivazione, scatole e quadri porta apparecchi | IMQ series - 0270 -
Boxes and enclosures for fittings*

1


IMQ S.p.A.

Descrizione della serie / Description of the series: univers

Width Larghezza (mm)	Depth profondità (mm)	Height Altezza (mm)	Code/Codice Enclosure plain door Quadro porta cieca	Code/Codice Plain door (spareparts) Porta cieca (ricambio)	Code/Codice Glazed door (spareparts) Porta vetro (ricambio)	Code/Codice Cable camp Guida Morsetti	Code/Codice Cable camp Guida Morsetti	Code/Codice Crosspiece Traversa
350	400	1900	FG21SD	FZ207SD	FZ216SD	UT11CN	FZ801N	UT81CN
600	400	1900	FG22SD	FZ208SD	FZ217SD	UT72CN	FZ802N	UT82CN
850	400	1900	FG23SD	FZ209SD	FZ218SD	UT73CN	FZ803N	UT83CN
1100	400	1900	FG24SD	FZ210SD+FZ211SD	FZ219SD+FZ220SD	UT74CN	FZ804N	UT84CN
1350	400	1900	FG25SD	FZ210SD+FZ215SD	FZ219SD+FZ224SD	UT75CN	FZ805N	UT85CN
1600	400	1900	FG26SD	FZ214SD+FZ215SD	FZ223SD+FZ224SD	UT76CN	FZ806N	UT86CN

Width Larghezza (mm)	Depth profondità (mm)	Height Altezza (mm)	Code/Codice Plain plate Pannello cieco	Code/Codice Sliding plate Pannello Scorrevole	Code/Codice Plinth H100 Zoccolo H100	Code/Codice Plinth H200 Zoccolo H200	Code/Codice Connection kit Kit accoppiamento	Code/Codice Sealing plate Piastra chiusura
350	400	//	FZ881SD	FZ891SD	FZ901SD	FZ931SD	FZ747S	FZ431N
600	400	//	FZ882SD	FZ892SD	FZ902SD	FZ932SD		
850	400	//	FZ883SD	FZ893SD	FZ903SD	FZ933SD		
1100	400	//	FZ884SD	FZ894SD	FZ904SD	FZ934SD		
1350	400	//	FZ885SD	FZ895SD	FZ905SD	FZ935SD		
1600	400	//	FZ886SD	FZ896SD	FZ906SD	FZ936SD		

Width Larghezza (mm)	Depth profondità (mm)	Height Altezza (mm)	Code/Codice Side Fianco
//	400	1900	FZ708SD

Descrizione della serie / Description of the series: univers

Code/Codice Enclosure plain door Quadro porta cieca	Dimensions / Dimensioni Height-Width-Depth (mm)	Static load Carico statico (Kg)
FG21SD	1900x350x400	61
FG22SD	1900x600x400	122
FG23SD	1900x850x400	183
FG24SD	1900x1100x400	244
FG25SD	1900x1350x400	305
FG26SD	1900x1600x400	366

CCA – CENELEC Certification Agreement
 Accord de Certification du CENELEC – CENELEC – Zertifizierungs – Abkommen

NOTIFICATION OF TEST RESULTS

Product EMPTY ENCLOSURES FOR LOW VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES

tested by request of HAGER LUMETAL S.p.A.

Via Pieve 27 – 33080 PORCIA PN - ITALY

manufactured at (name and place) HAGER LUMETAL S.p.A. – 33080 PORCIA PN - ITALY

Rating and principal characteristics IP54 closed door – IP30 opened door – T -5/+40°C – IK10 (see Test Report)

Preliminary visit carried out by IMQ

Trade mark (if any) hager (logo)

Model/Type Ref. univers (see Test Report)

Additional Information (if any) THIS PRODUCT IS COVERED BY A LICENCE OF IMQ MARK

IMQ APPROVAL CERTIFICATE No. CA02.02093

This NTR supersedes the previous one no. 23576/IMQ dated 2004-10-11

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition)

EN 62208:2003

as shown in the test report (reference No. 02LL00012)

This Notification of Tests Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Notification of Test Results has been established by a body which participates directly in the CENELEC Certification Agreement (CCA) of September 11th, 1973 as revised on March 29th, 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA.

20138 MILANO – Via Quintiliano, 43
 Telephone: (+39) 02-50731
 Telefax: (+39) 02-50991500
 e-mail: info@imq.it

IMQ S.p.A.

Internal ref.: M. CASARI

Date 2011-10-11

Signature, *Mano Verde*